

CERTIFICATE FI 28559



Our Ref. 275839-1

Product Emergency luminaire
Type TWT5051WK
Trade mark Teknoware
Certificate Holder / Manufacturer Teknoware Oy
 Ilmarisentie 8
 FI-15200 LAHTI, FINLAND
Technical information DS-5,5W; 220-240V; 50/60Hz; class I / III; IP20; ta 50°C; 159lm; emergency class Z0
Other information Centrally supplied non-maintained emergency luminaire
The product is certified according to the following standard(s) EN 60598-2-22:1998 + A1:2003 + A2:2008
 EN 60598-1:2008 + A11:2009

Validity This certificate is valid until 09 May 2019 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Directive information The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.

Date of issue 09 May 2014

SGS Fimko Ltd

Signature

Kari Vesterinen
 Product Line Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 28559

Manufacturing sites Teknoware Oy
Ilmarisentie 8
FI-15200 LAHTI, FINLAND

Additional information The product has CB certificate No. FI 8285 issued by SGS Fimko Ltd in accordance with the CB system.

As shown in the Test Report(s) No(s): 275839-1

UN